



Damage to CCGTs due to Cyclic Operation

Operational, Technical and Cost Issues

(Acronym: CCGT Cyclic Operation & Guidelines)

Final Report

ETD Report No: 1097-gsp-111

Principal Authors: **Dr D G Robertson, S Hampson, J P Fernandes**

Report checked by: **Dr I A Shibli**



ETD Consulting, Fountain House, Cleeve Road, Leatherhead, Surrey, KT22 7LX, UK
Tel: + 44 (0)1372 363 111 **Fax:** + 44 (0)1372 363 222 enquiries@etd-consulting.com
www.etd-consulting.com **BS EN ISO 9001: 2008 Certified** **VAT No: 733600853**
ETD Consulting is a trading name of European Technology Development Ltd, Registered in England No: 3553836

ETD Report No: **1097-gsp-111**

ETD Project No: **1097-gsp-proj07**

European Technology Development Limited

Leatherhead, Surrey

United Kingdom

enquiries@etd-consulting.com

www.etd-consulting.com

Disclaimer: European Technology Development Ltd. (ETD Consulting) has taken utmost care in the compiling and analysis of data and in the interpretation of the information supplied by the client. Whilst every effort has been made to ensure that the data provided in this report are correct and the advice or the guidelines given are of the highest standard and accuracy, neither ETD nor anyone acting on behalf of ETD makes any warranty, expressed or implied in any way, or accept any liabilities with respect to the use of any information, advice or methodology disclosed in this report.

Copyright: This Report has been produced by European Technology Development Limited (ETD) for the project sponsors, or any other body authorized in writing by ETD, only for use within their own organisation or on their clients' plant. No parts of this document may be photocopied or otherwise reproduced for distribution, sale, publication or use outside the sponsor's organisation without prior permission, in writing, from ETD.

Executive Summary

The on-going privatisation of electricity generation across the world, and the ensuing competition and demand by shareholders for higher profits has resulted in an increasing need to supply power on demand. As a result, Combined Cycle Gas Turbines (CCGTs) are increasingly being subjected to load-following and/or two-shifting / cyclic operation. However, cyclic operation can introduce new types of damage and higher rates of damage, and hence result in increased maintenance and repair costs. In this study, the basic causes of these higher costs are examined, with a view to reducing them through improvements in operating, inspection and maintenance procedures.

Relatively small differences in costs and reliability can make a large difference in the station ranking. Many of the early, less efficient CCGTs have been downgraded to two-shifting operation. However, once a unit is subject to cyclic operation, reliability can suffer. This means that there is a danger of a vicious spiral setting in, so that more cyclic operation leads to more unreliability, which leads to more cyclic operation.

Even new CCGT units may need to be operated in cyclic mode prematurely. Power from hydro, wind and solar energy sources cannot be scheduled in the same way as that from fossil fuel or nuclear plant. Most combined heat and power systems operate in base-load mode, leaving the peaks to be picked up by large centralised stations. Both trends imply further increase in cyclic operation and load-following in future.

The principal aims of this study were to collate, critically analyse and review available information and experience on the operation of combined cycle plant under cycling conditions. Specific objectives were:

- To identify the key engineering threats;
- To identify operational constraints;
- To assess the impact on engineering and operating costs;
- To provide guidelines on how to solve the problems associated with cyclic operation.

The information presented in this report has been obtained from ETD's surveys of plant experience, visits to plants, personal contacts, and reviews of recently published literature. This review is a follow-up of an earlier investigation conducted by ETD in 2002 which was sponsored by a number of industries from Europe and North America. Since that study many new developments have taken place, including the expansion of CCGT cycling experience worldwide, use of new materials, new designs to incorporate fatigue damage, new R&D findings, and so on. It was thus an appropriate time for the cataloguing and critical review of such experience and for producing guidelines that need to be followed to reduce damage to components, increase plant reliability and reduce cost of plant operation and maintenance.

The report starts with discussion of the background to cyclic operation and then reviews the evolution of CCGT plant (design, construction and materials), and how this has influenced the ability to cycle. Earlier plants comprised a number of low output gas turbines and HRSGs feeding into a single steam turbine which gave good flexibility, whereas modern units consist of a single large output gas turbine and HRSG and there is concern about the ability of such plants to respond to and combat frequency changes in the Grid. Earlier designs of HRSGs were very poor in cycling situations, primarily because of difficulties with condensate removal. Manufacturers are now aware of these problems, but newer HRSG units are larger and operate in the creep-fatigue range, and hence thermal stressing is still a serious concern.

A comprehensive review of the likely damage and maintenance issues under cyclic operating conditions is given in separate sections for the gas turbine, HRSG, steam turbine and electrical equipment. The root causes of problems affecting the GT hot section components are discussed, including thermo-mechanical fatigue of blades and vanes, coatings and environmental effects, and microstructural degeneration. Background information on oxidation-resistant coatings and implications for blade cracking, and thermal barrier coatings and implications for repair and renewal is provided in the appendices.

For the HRSG, there is a discussion of the impact of design, start-up times, materials and weldment issues, and operational aspects including differential thermal expansion and drainage and condensate issues. As well as damage to superheater and reheater components, the implications of cyclic operation for economisers, steam drums, casings and other structures, and valves are considered. There is comprehensive discussion of water treatment and water-side corrosion issues, including flow-assisted corrosion and corrosion-fatigue. Acid dew-point corrosion and stress corrosion cracking on the gas-side of economiser and preheater tubing are also discussed.

The root causes of problems affecting steam turbines, generators and other electrical equipment under cyclic operating conditions are also discussed. For the steam turbine, the main issues are thermal fatigue of thick-section components, and droplet corrosion and environmentally-assisted cracking in the LP turbine.

In a separate section of the report, the results of ETD's survey of CCGT plant operator experience are presented and discussed. This includes feedback on the specific problems of individual plants, maintenance and inspection, modifications to plant equipment and operating procedures, manpower levels and staff training requirements, and other issues.

The report also includes a section on monitoring and inspection techniques for gas turbines, HRSGs, steam turbines and electrical equipment. This section covers monitoring and diagnostic techniques for gas turbines, monitoring guidelines for HRSGs, and vibration monitoring of power plant equipment. Additional background information on the on-line component life utilisation software systems is given in an appendix.

Guidelines on the engineering strategies for dealing with the problems arising due to cyclic operation are presented in separate Tables for GT components, HRSG components, ST components, and electrical equipment. The Tables present a summary of the main problems based on operator experience. For each potential problem, an estimate is given of the likelihood of the problem occurring and the impact that the problem could have on plant availability. The engineering strategies/solutions are provided as guidance for development by users to suit their plant requirements.

Finally, the report contains a section on the costs associated with cyclic operation, including a discussion of manpower costs, fuel costs, loss of potential output, availability and reliability assessment, increased maintenance and plant modifications, and assessment of start-up, maintenance and inspection costs. ETD has developed a 'model unit' approach for analyzing the operating costs of different plants and which can be used for *benchmarking* purposes. This model can also be used for future cost predictions based on the plant historical data, plant size, age and other such information.

This report is intended to be read and used by:

- Plant operators with limited experience of cyclic operation of CCGTs;
- Plant operators with advanced experience but who wish to compare their experience with that of others;
- Experienced operators who wish to use and develop check lists to help improve station practices;
- Operators with limited in-house technical support;
- New owners of CCGTs;
- Plant manufacturers and designers.

=====

CONTENTS

	Page No.
Executive Summary	3
1. INTRODUCTION	10
2. STUDY OBJECTIVES	12
3. BACKGROUND	13
4. TYPES OF CYCLIC OPERATION	16
5. EVOLUTION OF CCGT PLANT AND IMPLICATIONS FOR CYCLIC OPERATION	17
5.1. Changes to Plant Layout	17
5.2. CCGT Plant Limitations in respect of Cycling	17
5.3. Gas Turbine Design and Materials	20
5.3.1. State-of-the-art	20
5.4. HRSG Design and Construction	26
5.4.1. Materials of construction	26
5.4.2. Type of HRSG	27
5.4.2.1. <i>Horizontal HRSGs</i>	28
5.4.2.2. <i>Vertical HRSGs</i>	28
5.4.2.3. <i>Once-Through Steam Generator (OTSG)</i>	30
5.4.3. Design of pressure parts for HRSGs	33
5.5. Steam Turbine Design and Construction	34
5.6. Alternator Design and Construction	36
6. GAS TURBINES - KEY ENGINEERING THREATS & MAINTENANCE ISSUES	38
6.1. Maintenance Issues under Cyclic Operating Conditions	38
6.1.1. Turbine section	38
6.1.2. Combustion section	40
6.1.3. Compressor and ancillaries	40
6.1.4. Auxiliaries	41
6.2. Root Causes of Problems affecting GT Hot Section Components	43
6.2.1. Thermo-mechanical fatigue - blades and vanes	44
6.2.2. Other transient considerations	46
6.2.3. Coatings and environmental effects	46
6.2.4. Blade issues	49
6.2.5. Microstructural degeneration and thermo-mechanical fatigue susceptibility	54
6.2.6. Braze repair	58
6.3. Guidelines for Engineering Solutions to Cycling-related Problems	60
7. HEAT RECOVERY STEAM GENERATORS – POTENTIAL DAMAGE & MAINTENANCE ISSUES	67
7.1. Damage Mechanisms under Cyclic Operating Conditions	67
7.2. Impact of HRSG Design	69

7.3.	Start-up Times	71
7.4.	Materials and Weldment Issues	72
7.5.	Operational Aspects	75
7.5.1.	Tube expansion and stresses due to temperature differences	75
7.5.2.	Drainage and condensate issues	80
7.5.3.	Economiser issues	86
7.5.4.	Steam drum issues	90
7.5.5.	Cyclic life assessment of HRSG components	91
7.5.6.	Casings, ducts, stacks & other structures	93
7.5.7.	Valves	95
7.6.	Boiler Water Treatment in HRSG Systems	98
7.6.1.	Water treatment guidelines and control of FAC	103
7.7.	Water-side Corrosion Issues	105
7.7.1.	High iron concentrations in evaporators	105
7.7.2.	Iron release from air-cooled condensers	109
7.7.3.	Corrosion-fatigue from waterside in economisers	111
7.8.	Gas-side Corrosion Issues	114
7.8.1.	Formation of corrosive deposits on the gas-side of preheater and cool economiser tubes during low load operation	114
7.8.2.	Corrosion and stress corrosion cracking arising from corrosive materials deposited on the gas-side of preheaters and economisers	118
7.9.	Guidelines for Engineering Solutions to Cycling-related Problems	121
8.	STEAM TURBINES - POTENTIAL DAMAGE & MAINTENANCE ISSUES	122
8.1.	Maintenance Issues for ST Components under Cyclic Operating Conditions	122
8.2.	Root Causes of Problems affecting ST Components	124
8.2.1.	Thermal fatigue and creep-fatigue due to thermal cycling	124
8.2.2.	Mechanical fatigue due to load and speed variations	125
8.2.3.	Differential expansion of turbine rotors and casings	125
8.2.4.	Erosion of turbine blades	126
8.2.5.	Environmentally-assisted cracking in LP turbine	126
8.2.6.	Valves	127
8.2.7.	Bearings	127
8.3.	Guidelines for Engineering Solutions to Cycling-related Problems	128
9.	ELECTRICAL EQUIPMENT - POTENTIAL DAMAGE & MAINTENANCE ISSUES	134
9.1.	Maintenance Issues for Electrical Components under Cyclic Operating Conditions	135
9.2.	Root Causes of Problems affecting Generators and Other Electrical Components	136
9.2.1.	Rotors	136
9.2.2.	Stators	137
9.2.3.	End rings	138
9.2.4.	Electric motors	138
9.2.5.	Transformers	138

9.3.	Guidelines for Engineering Solutions to Cycling-related Problems	139
10.	PLANT MONITORING AND INSPECTION TECHNIQUES	143
10.1.	Monitoring and Inspection of Gas Turbines	143
10.1.1.	Monitoring & diagnostics	144
10.1.2.	Optical pyrometer for monitoring blade temperature	147
10.1.3.	On-line thermal imaging	148
10.1.4.	Electrostatic debris monitoring	151
10.1.5.	Acoustic thermography	154
10.2.	Component Monitoring Guidelines for HRSGs	156
10.2.1.	Temperature monitoring for assessment of thermal fatigue damage	156
	10.2.1.1. Data collection and analysis	160
10.2.2.	On-line component life utilisation software systems	160
10.2.3.	Chemical monitoring of HRSGs	162
10.3.	Monitoring of Steam Turbines	162
10.3.1.	Rotor torque monitoring system for fatigue life calculation	165
10.4.	Vibration Monitoring Systems for Power Plant	166
10.5.	NDE of Steam Turbine Rotors	170
11.	SURVEY OF PLANT OPERATOR EXPERIENCE	173
11.1.	General Experience of Problems / Damage due to Cyclic Operation	173
11.2.	Specific Problems of Individual Plants	175
11.2.1.	Gas turbines	175
11.2.2.	HRSG units	177
11.2.3.	Steam turbines	180
11.2.4.	Other equipment	181
11.3.	Plant Maintenance & Inspection	182
11.4.	Plant Equipment & Operating Procedures	183
11.5.	Manpower Levels & Staff Training	184
11.6.	Other Issues	185
12.	COST CONSIDERATIONS IN PLANT CYCLING	186
12.1.	Introduction	186
12.2.	Manpower	187
12.3.	Fuel	188
12.4.	Loss of Potential Output	191
12.5.	Availability and Reliability Assessment	193
	12.5.1. FOR and SOR analysis of CCGT power plants	195
12.6.	Increased Maintenance and Plant Modifications	199
12.7.	Overall Cost Implications of Cyclic Operation	202
12.8.	Cost Assessment	202
	12.8.1. Operational cost assessment	203
	12.8.2. Capital and major item replacement costs	203
	12.8.3. Start-up cost assessment	204
	12.8.4. Inspection cost assessment	206
	12.8.5. Maintenance cost assessment	209
	12.8.6. Management cost assessment	211

12.9. Recommendations to Reduce Costs	213
13. CONCLUSIONS	214
REFERENCES	218

APPENDICES

Appendix 1

Oxidation Resistant Coatings and Implications for Blade Cracking	225
--	-----

Appendix 2

Thermal Barrier Coatings and Implications for Repair and Renewal	230
--	-----

Appendix 3

Condensate Build-Up and Drainage in HRSGs	234
---	-----

Appendix 4

Guidelines for Engineering Solutions to Problems arising from Thermal Cycling of HRSGs	236
--	-----

Appendix 5

Component Life Monitoring Software Systems for Boilers / HRSGs	266
--	-----